



GENERAL NOTES:

1- METAL BODY OF ALL EQUIPMENT SHOULD BE CONNECTED TO EARTHING SYSTEM WITH 16mm<sup>2</sup> NYAF WIRE AND CABLESHOES.

2- 70mm<sup>2</sup> COPPER WIRE SHOULD BE PULLED ON THE CABLE TRAY.

3- INSTALLATION HEIGHT OF EARTH BAR SHALL BE 50cm ABOVE FINISHED FLOOR.

KEY PLAN

THIS LOCATION

00	1399/04/26	IFA
REVISION NO.	DATE	DISCRIPTION
PROJECT:		
شرکت توسعه آهن و فولاد گل گهر		
Golgozar Iron & Steel Development Co.		
G.I.S.D.Co		
PROJECT: Golgozar Steel Project		
PROJECT DRAWING No.		REV
DRAWING TITLE :		
DRP KITCHEN		
EARTHING SYSTEM LAYOUT		
DESIGNED	M.OMRANIAN	1399/04/20
DRAWN	M.ALIPOUR	1399/04/26
CHECKED	M.OMRANIAN	1399/04/27
APPROVED	A.GOUDARZI	1399/04/31
SCALE		
NTS		
SIZE		
A1		
PROJECT REF. NO.		
157DEGB1045009		

ROOM LIST	
ROOM No.	ROOM NAME
1	HEAD OFFICE
2	GENERAL KITCHEN STORAGE
3	REFRIGERATOR
4	VEGETABLE PREPARATION
5	EXTERNAL STORAGE
6	KABAB COOKING
7	HVAC ROOM
8	CORRIDOR
9	KITCHEN STAFF ROOM
10	KITCHEN AREA
11	WASHING
12	GARBAGE AREA
13	LOCKERS
14	J.C.
15	SHOWER
16	TOILET
17	ELEC. ROOM
18	STAFF AIR LOCK
19	WEIGHT AREA
20	ENTRANCE AREA